

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by **Mr. Vijayakumar Hanagodimath, Public Development Officer** from Grama Panchayth Office, Rahutanakatti inspected the K. V. Central School, Srinivasapura, Medleri Road, Ranebennur Tq. on 31.03.2026 and on the basis of Water Test Report (Attached) bearing no.: NTLR/7.8/F/01-CM/09 dated 14/07/2025 of NTLR Lab certified that the K. V. Central School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till up to two years.

Signature with Seal : 

Name : **ಪಂಚಾಯತ ಅಭಿವೃದ್ಧಿ ಅಧಿಕಾರಿ**



Designation : **ಗ್ರಾಮ ಪಂಚಾಯತ, ರಾಹುತನಾಕಟ್ಟೆ**

Name & Address of the Office / Department :


SL. No 0179
24.04.2026

To,
The Principal
K. V. Central School
Srinivasapura,
Medleri Road,
Ranebennur Tq.
Haveri District.

Panchayath Development officer
Goamapanchath
Rahuthanakatte
Ranebennur Tq. Haveri Dist.

ATTESTED BY ME

NOTARY PUBLIC
24.04.2026


Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


SECRETARY
K.V. Education Society
Ranebennur

Thippeswamy. G.
PRINCIPAL
K.V. Central School
Ranebennur

MoEF & CC / CPCB Recognised
 ISO/IEC 17025:2017 Accredited
 (NABL TC-6990)
 ISO 9001:2015 Certified
 ISO 45001:2018 Certified



CIN: U74900KA2013PTC069193

**NICHROME TESTING LABORATORY
 AND RESEARCH PRIVATE LIMITED**

170, 2nd MAIN JUDGES BUNGALOW ROAD, HARAYANPUR
 DHARWAD, KARNATAKA, INDIA PIN: 580 008
 PH: 0836-2771115, 2778521

email: nicechem@gmail.com, website: nichromelabs.com

TESTING / CONSULTING / ENGINEERING / TRAINING

MOU WITH VARIOUS EDUCATIONAL,
 GOVERNMENT AND PRIVATE AGENCIES

TC-6990

Format No: NTLR/7.8/F/01-CM/09

Page 1 of 1

TEST REPORT

Name of Customer and Address:

K V Central School,
 Shrinivasapur, Medleri Road,
 Ranebennur-581115

ULR Code No:

TC699025000004602F

Report Number:

NTLR/JULY/4818

Sample Number:

JULY/25/4818

Type of Sample:

DRINKING WATER

Discipline :

Chemical & Biological

Group:

Water

Customer Reference:

NA

Sample Collected by:

Customer

Sampling Method:

-

Particulars of Sample Collected:

-

Environmental Condition:

26° C

Date of Collection:

10/07/2025

Date of Sample Receipt:

10/07/2025

Date of Analysis Started:

10/07/2025

Date of Completion:

14/07/2025

Date of Report:

14/07/2025

Sample Condition:

Satisfactory

Specification Standard:

IS 10500 : 2012

Sampling Location:

NA

Sample Description:

1Ltr Pet Bottle & 300ml Sterilized Bottle

RESULTS

SLNO	PARAMETERS	UNITS	TEST METHOD	RESULT	STANDARD	
					Acceptable Limits	Permissible Limits
Physico-chemical Parameters						
1	Colour, Max	Hazen Units	IS 3025 (Part 4)-a	BDL	5	15
2	Total Dissolved Solids (TDS), Max	mg/L	IS 3025 (Part 16)	80.0	500	2000
3	pH@ 25°C	-	IS 3025 (Part 11)	6.80	6.5 - 8.5	No relaxation
4	Total Alkalinity as CaCO ₃ , Max	mg/L	IS 3025 (Part 23)	36.1	200	600
5	Total Hardness (TH) as CaCO ₃ , Max	mg/L	IS 3025 (Part 21)	54.5	200	600
6	Nitrate (as NO ₃), Max	mg/L	IS 3025 (Part 34)-b	1.80	45	No relaxation
7	Chloride (as Cl), Max	mg/L	IS 3025 (Part 32) Argentometric	14.6	250	1000
8	Sulphate (as SO ₄), Max	mg/L	IS 3025 (24/Sec1)	12.4	200	400
9	Calcium (as Ca), Max	mg/L	IS 3025 (Part 40)	12.9	75	200
10	Magnesium (as Mg), Max	mg/L	IS 3025 (Part 46)	5.40	30	100
11	Fluoride (as F), Max	mg/L	APHA 4500F, D	0.13	1.0	1.5
12	Iron as Fe, Max	mg/L	IS 3025 (Part 53)-a	BDL	1.0	No relaxation
13	Turbidity, Max	NTU	IS 3025 (Part 10)	BDL	1	5
Bacteriological Parameters						
14	Total Coliforms	Presence/Absence per 100 mL Sample	IS :15185	Absent	Requirement Absent/100 mL	
15	E.coli		IS :15185	Absent	Absent/100 mL	

BDL- Below Detectable Limit, (Colour - 1 Hazen units, Iron-0.05mg/L, Turbidity-1NTU)

Inference as per IS 10500 : 2012 Standards

Above tested parameters are conforming to standard.

Note: 1. Sample received is the only source of water as per customer. Hence permissible limits considered. 2. As per IS 10500:2012 acceptable limit is to be implemented. In absence of alternative source, Permissible limits shall be considered. 3. Refer IS 10500:2012 for drinking water standards detailed information for all parameters

Authorized Signatory
 Ambarish Sindagi (Microbiology)

Authorized Signatory
 Channabasappa Maikar (Chemical)

..END OF REPORT..

Note:

1 The results listed above pertain only to the tested samples and applicable parameters. 2 Samples which are degradable, unstable will be disposed immediately after testing and others will be disposed after 15 days from the date of issue of test report unless otherwise specified. 3 Total liability of our laboratory is limited to the invoiced amount. 4 This report is not to be reproduced either wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without prior written permission. 5 Statement of conformity is made where specifications are available and not in judgement while making statement of conformity. 7 If any dispute is subject to Dharmwad Jurisdiction. 8 When laboratory is required by law contractual agreements to release confidential information, the customer shall be informed unless prohibited by law. 9 Samples are to be tested as per methods specified. 10 Any discrepancy in the test report should be notified within 15 days of issue of report. Complaints kindly register in our Complaint Register maintained by our Customer Service Coordinator.

SECRETARY
 K.V. Education Society
 Ranebennur

PRINCIPAL
 K.V. Central School
 Ranebennur